

UL/cUL SYSTEM NO. F-A-1194 METAL PIPE THROUGH CONCRETE FLOOR OVER METAL DECK ASSEMBLY		
F-RATING = 2-HR. T-RATING = 2-HR. L-RATING AT AMBIENT = LESS THAN 1 CFM / SQ L-RATING AT 400°F = LESS THAN 1 CFM / SQ FT		-A1194c.111319
		FA
1. LIGHTWEIGHT OR NORMAL WEIGHT CONCRETE FLOOR (MINIMUM 2-1/2" TH ASSEMBLY (UL/cUL CLASSIFIED D900 SERIES) WITH 2" OR 3" FLUTED DECK 2. HILTI CFS-CID MD PLT [W2" OR W3"] METAL DECK PLATFORM SECURED TO	(S (2-HR. FIRE-RATI	NG).
IN EACH CORNER. 3. HILTI CFS-CID MD [P OR PX] [2", 3", OR 4"]/[2.5" OR 4"] FIRESTOP CAST-IN DEVICE FOR METAL DECK SECURED TO HILTI CFS-CID MD PLT METAL DECK PLATFORM WITH SCREWS. THE 2.5" HEIGHT DEVICES ARE INTENDED FOR A 2-1/2" CONCRETE TOPPING AND THE 4" HEIGHT DEVICES ARE FOR CONCRETE		
TOPPINGS GREATER THAN 2-1/2" THICK. 4. PENETRATING ITEM TO BE ONE OF THE FOLLOWING : A. MAXIMUM 4" NOMINAL DIAMETER STEEL PIPE (SCHEDULE 40 OR HEAVIER).		
B. MAXIMUM 4" NOMINAL DIAMETER CAST OR DUCTILE IRON PIPE. C. MAXIMUM 4" NOMINAL DIAMETER STEEL CONDUIT OR EMT. 5. DUCT WRAP (NOMINAL 1-1/2" OR 2" THICK FYREWRAP 2.0 DUCT INSULATION OR FIREWRAP DUCT INSULATION [MANUFACTURED BY UNIFRAX] OR NOMINAL 1-1/2" THICK FIREMASTER FASTWRAP XL		
DUCT INSULATION [MANUFACTURED BY THERMAL CERAMICS]) WRAPPED AROUND PENETRANT, EXTENDING 24" ABOVE THE FLOOR. AN ADDITIONAL LAYER OF DUCT WRAP TIGHTLY WRAPPED AROUND THE FIRST LAYER OF DUCT WRAP, EXTENDING 12" ABOVE FLOOR, SEAMS TO OVERLAP MINIMUM 1" AND SEALED WITH FOIL TAPE.		
HILTI, Inc. HILTI Firestop Systems	Sheet 2 of 2 Scale - Date Nov. 13, 2019	Drawing No. FA 1194c

Saving Lives through Innovation and Education