

CERTIFICATE OF COMPLIANCE

Certificate Number 20170711-R15431
Report Reference R15431-20170710
Issue Date 2017-JULY-11

Issued to: HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC
7250 Dallas Pky, Legacy Tower Ste 1000
Plano TX 75024

This is to certify that representative samples of FIRESTOP DEVICES
Models CFS-CID M 8" and 10"; CFS-CID P 8" and 10"

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1479, Fire Tests of Penetration Firestops
CAN/ULC S115, Methods of Fire Tests of Firestop Systems

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

