

Certificate of Compliance



You have been awarded:

Intertek ETL C + US Mark for Firestop Systems

Standards: ASTM E2307 (2015), CAN / ULC S115 (2018) Ed. 5

Certificate number: WHI19-23235504

Organization: Hilti Corporation
Feldkircherstrasse 100
FL-9494
Schaan
Principality of Liechtenstein

Product: Hilti Corporation - CFS-EOS QS Perimeter Fire Barrier System
Spec ID: 49062
RATINGS
ASTM E2307
CAN/ULC S115
CFS-EOS QS Perimeter Fire Barrier System
ASTM E 2307 & CAN/ULC S115
System Number F-Rating T-Rating
HI/BPF 120-18 2-Hour 33 Min
HI/BPF 120-19 2-Hour 33 Min

Certification body: Intertek Testing Services NA, Inc.
Initial registration: July 11, 2019
Date of expiry: July 11, 2024
Issue status: 1

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Charles Meyers
Certification Manager

Name

Signature

7/15/2019
Date

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

www.intertek.com