

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	4485-1200:0135
CATEGORY:	4485 - OPENING PROTECTION (FIRESTOPPING)
LISTEE:	HILTI, INC. 5400 S 122nd East Ave., Tulsa, OK, 74146 Contact: Winston, Matthew (214) 803-5721 (918) 254-1679 Email: matthew.winston@hilti.com
DESIGN:	Type CP680-P (may include a size designation suffix) Cast-in Firestop Devices for use in through penetration systems. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	See approval
INSTALLATION:	In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, classification and UL label.
APPROVAL:	Listed as cast-in firestop device for use in through penetration system when constructed and installed in accordance with UL Fire Resistance Directory. Approved systems: F-A-1016 and F-A-2054.
NOTES:	



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/10/2025 Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator Fire Engineering & Investigations Division