

# Confirmation

## LEED

On 26 August 2019, Eurofins Product Testing A/S received a sample of a firestop with the product name:

**CFS-CID MD M 3"/4" Black**

supplied by

**Hilti, Inc**


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH 01350 testing standard (See test report no. 392-2019-00322910\_H\_EN).

**The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

1 October 2019



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*