

Confirmation

LEED

On 26 August 2019, Eurofins Product Testing A/S received a sample of a firestop with the product name:

CFS-CID MD M 4"/4" Black

supplied by

Hilti, Inc


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH 01350 testing standard (See test report no. 392-2019-00322906_H_EN).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

1 October 2019



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.