

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130124-R15431  
**Report Reference** R15431-20130123  
**Issue Date** 2013-JANUARY-24

**Issued to:** HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC  
5400 S 122ND EAST AVE  
TULSA OK 74146



**This is to certify that  
representative samples of** FIRESTOP DEVICES  
See addendum page for products covered.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 1479, "Fire Tests of Through-Penetration  
Firestops."  
CAN/ULC-S115-2005, "Standard Method of Fire Tests of  
Firestop Systems."

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Classification Mark for the U.S. and Canada should be considered as being covered by UL's Classification and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Classification Mark includes: the UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory. The UL Classification Mark for Canada includes: the UL Classification Mark for Canada:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) in English, French, or English/French as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130124-R15431  
**Report Reference** R15431-20130123  
**Issue Date** 2013-JANUARY-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**Products covered:**

Firestop devices for use in specific through-penetration firestop systems. The number suffixes for the designations of the firestop devices indicate the size of the device.

Models: Firestop Sleeve Kit, CFS-SL SK 2" and 4", Firestop Retrofit Sleeve Kit, CFS-SL RK 2" and 4"



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

