

**DWMU.E217969**  
**Conduit and Cable Hardware**[Page Bottom](#)

---

**Conduit and Cable Hardware**[See General Information for Conduit and Cable Hardware](#)**HILTI INC**

E217969

7250 Dallas Pky , Legacy Tower Suite 1000  
Plano, TX 75024 USA

Trademark and/or Tradename:

**Power Fastened Cable Supports**, Model(s) X-BX 3/8? may be followed by suffix MX, C27, or U27**Power Fastened EMT Supports**, Model(s) X-EMTSC 1/2", X-EMTSC 3/4", X-EMTSC 1?, X-EMTC 1/2" may be followed by suffix MX, C27, or U22**Power fastened hangers for use with steel or concrete**, Model(s) X-HS W10, X-HS W10 U19 P8 S15, X-HS W10 U22 P8 S15, X-HS W10 U32 P8 S15, X-HS W6, X-HS W6 U19 P8 S15, X-HS W6 U22 P8 S15, X-HS W6 U32 P8 S1, X-RH1/4-U27-P8T[Last Updated](#) on 2015-12-01

---

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".