




Classified by
Underwriters Laboratories, Inc.
to UL 2079 and CAN/ULC-S115


System No. HW-D-0633

HWD 0633


ANSI/UL2079	CAN/ULC S115
Assembly Ratings — 1 and 2 Hr (See Item 2)	F Ratings — 1 and 2 Hr (See Item 2)
Nominal Joint Width - 1 In.	FT Ratings — 1 and 2 Hr (See Item 2)
	FH Ratings — 1 and 2 Hr (See Item 2)
	FTH Ratings — 1 and 2 Hr (See Item 2)
	Nominal Joint Width - 25mm
Class II or III Movement Capabilities — 25% Compression or Extension	Class II or III Movement Capabilities — 25% Compression or Extension
L Rating at Ambient — Less than 1 CFM/Lin Ft	L Rating at Ambient — Less than 1.55 L/s/m
L Rating at 400°F — Less than 1 CFM/Lin Ft	L Rating at 400°F — Less than 1.55 L/s/m




CONFIGURATION A



SECTION A-A



CONFIGURATION B



CONFIGURATION C



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
March 06, 2018

1. Floor Assembly — The fire-rated fluted steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D900 Floor-Ceiling Design in the UL Fire Resistance Directory. The hourly fire rating of the floor assembly shall be equal to or greater than the hourly fire rating of the wall assembly. The floor assembly shall include the following construction features:

A. Steel Floor and Form Units* — Max 3 in. (76 mm) deep galv fluted floor units.

B. Concrete — Min 2-1/2 in. (64 mm) thick reinforced (100-150 pcf or 1600-2400 kg/m³) concrete, as measured from the top plane of the floor units.

1A. Roof Assembly — As an alternate to Item 1, the fire-rated roof assembly shall be constructed of the materials and in the manner described in the individual P900 Series Roof-Ceiling Designs in the UL Fire Resistance Directory and shall contain max 3 in. (76 mm) deep galv steel fluted roof units. The hourly fire rating of the roof assembly shall be equal to or greater than the hourly fire rating of the wall assembly.

Firestop Configuration A

2. Wall Assembly — The 1 hr or 2 fire rated gypsum board/steel stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:

A. Steel Floor Runners — Floor runners of wall assembly shall consist of galv steel channels sized to accommodate steel studs (Item 2C).

B. Light Gauge Framing* - Slotted Ceiling Runner — Slotted ceiling runner to consist of galv steel channel with slotted flanges sized to accommodate steel studs (Item 2C). Slotted ceiling runner installed perpendicular to direction of fluted steel deck secured to valleys (Configuration A) or parallel to direction of fluted deck secured to valleys or corrugated steel straps (Configuration B and C) with typical steel fasteners or welds spaced max 24 in. (610 mm).

SAFTI SEAL INC — ST, STW or STX

MRI STEEL FRAMING LLC — Smart Slotted Track

SUPER STUD BUILDING PRODUCTS — Slotted Track

C Studs — Steel studs to be min 3-1/2 in. (89 mm) wide. Studs cut 1/2 to 3/4 in. (13 to 19 mm) less in length than assembly height with bottom nesting in and resting on floor runner and with top nesting in ceiling runner (Item 2B) steel studs secured to slotted ceiling runner with No. 8 by 1/2 in. (13 mm) long wafer head steel screws at mid-height of slot on min. one side of wall. Stud spacing not to exceed 24 in. (610 mm) OC.

D. Gypsum Board* — Gypsum board sheets installed to a min total thickness of 5/8 in. (16 mm) and 1-1/4 in. (32 mm) on each side of wall for 1 and 2 hr rated assemblies, respectively. Wall to be constructed as specified in the individual Wall and Partition Design in the UL Fire Resistance Directory, except that a nom 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the bottom of the steel floor units and the top row of screws shall be installed into the studs a min. 4 in. (102 mm) below the lower surface of the floor. The hourly fire rating of the joint system is equal to the hourly fire rating of the wall.

3. Joint System — Max separation between bottom flange of the deflection track and top of wallboard (at the time of installation of the joint system) is 1 in. (25 mm). The joint system is designed to accommodate a max 25 percent compression or extension from its installed width. The joint system consists of:

A. Forming Material* — Min 4 pcf (64 kg/m³) density mineral wool batt insulation cut approx 33 percent wider than the flutes, approx 33 percent thicker than the depth of the steel deck, and with a length equal to the overall width of the wall. Mineral wool compressed and inserted into flutes of the steel floor units between top of ceiling runner and the steel deck.

INDUSTRIAL INSULATION GROUP L L C — MinWool-1200 Safing

JOHNS MANVILLE — Safing

ROCK WOOL MANUFACTURING CO — Delta Board or Delta-8

ROCKWOOL — Type Safe

THERMAFIBER INC — Type SAF



A1. Forming Material* — Plugs — As an alternate to Item 3A, preformed mineral wool plugs, formed to the shape of the fluted floor units, friction fit to completely fill the flutes above the ceiling runner. The plugs shall project beyond the finished side of the ceiling runner, flush with wall surface.

ROCK WOOL MANUFACTURING CO — Delta Deck Plugs

A2. Forming Material* — Plugs — As an alternate to Item 3A and for use only with Hilti Firestop Sprays (CP 672, CFS-SP WB), preformed mineral wool plugs, formed to the shape of the fluted floor units, friction fit to completely fill the flutes above the ceiling runner. The plugs shall project beyond the finished side of the ceiling runner, flush with wall surface.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP777 Speed Plugs

B. Forming Material* — Min 4 pcf (64 kg/m³) density mineral wool batt insulation cut to a thickness twice larger than the distance between the top of the gypsum board and the bottom of the steel floor unit. Material compressed 50 percent and installed within ceiling runner above top of liner panel flush with the inside surface of the panel. Material compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the steel floor units, flush with the surface of the wall.

INDUSTRIAL INSULATION GROUP L L C — MinWool-1200 Safing

JOHNS MANVILLE — Safing

ROCK WOOL MANUFACTURING CO — Delta Board

ROCKWOOL — SAFE

THERMAFIBER INC — Type SAF

B1. Forming Material* - Strips — As an alternate to Item 2B and for use only with Hilti Firestop Sprays (CP 672, CFS-SP WB), the strips are stacked to a height twice larger than the distance between the top of the gypsum board and the bottom of the steel floor unit. Strips compressed 50 percent and installed within ceiling runner above top of liner panel flush with the inside surface of the panel. Strips compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the steel floor units, flush with the surface of the wall.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP 767 Speed Strips

C. Fill, Void or Cavity Material* — Min 1/16 in. (01.6 mm) dry, (1/8 in. or 3.2 mm wet) thickness of fill material sprayed or brushed on each side of the wall in the flutes of the steel floor units and between the top of the gypsum board and the bottom of the steel floor units to completely cover mineral wool and overlap a min of 1/2 in. (13 mm) onto gypsum board and steel deck on both sides of wall.

3M COMPANY — Firedam Spray 200

A/D FIRE PROTECTION SYSTEMS INC — A/D FireBarrier Spray Acrylic

EGS NELSON FIRESTOP — FSC 3

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP672, CFS-SP WB Firestop Joint Spray

PASSIVE FIRE PROTECTION PARTNERS — 3500 SI, 5100 SP

RECTORSEAL — Metacaulk 1200 spray, Biostop 750 spray

SPECIFIED TECHNOLOGIES INC — SpecSeal AS200

TREMCO INC — TREMstop Acrylic SP

UNITED STATES GYPSUM CO — Type SA

C1. Fill, Void or Cavity Material* — Tape — As an alternate to the 3M Firedam Spray 200 (see Item C), Tape cut to size and press applied within fluted areas of joint to completely cover mineral wool lapping min 1 in. (25 mm) onto the contour of the steel floor units and extending to lap min 1 in. (25 mm) onto the gypsum wall. Additional pieces of Tape are applied along the joint to completely cover the remaining mineral wool between bottom of steel deck and top edge of wall along length of joint, lapping min 1 in. (25 mm) onto the contour of the steel floor units and min 1 in. (25 mm) onto the gypsum wall. Adjoining lengths of Tape shall overlap min 1/2 in. (13 mm). Tape shall be applied at both sides of wall.

3M COMPANY — 3M Fire and Water Barrier Tape



Firestop Configuration B

2. Corrugated Steel Straps* — A continuous length of min No. 20 ga galv corrugated steel strap to span the flute with ribs extending into flute cavity at the intersection of the valley surface and flute walls and overlapping the adjacent valleys 1 1/2 in. (38 mm). The steel strip is to be fastened to the floor assembly with typical steel fasteners or welds 16 in. (406 mm) O.C on both valleys. When wall length exceeds length of strap, straps are to be tightly butted or overlapped and fastened a max 2 in. (51 mm) from ends.
SAFTI SEAL INC — Safti-Frame FC (Flute Cover) Series
3. Wall Assembly — The 1 hr or 2 fire rated gypsum board/steel stud wall assembly shall be constructed of the materials and in the manner described in the individual U400 or V400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:
 - A. Steel Floor Runners — Floor runners of wall assembly shall consist of galv steel channels sized to accommodate steel studs (Item 3C).
 - B. Light Gauge Framing* - Slotted Ceiling Runner — Slotted ceiling runner to consist of galv steel channel with slotted flanges sized to accommodate steel studs (Item 3C). Slotted ceiling runner installed perpendicular to direction of fluted steel deck secured to valleys (Configuration A) or parallel to direction of fluted deck secured to valleys or corrugated steel straps (Configuration B and C) with typical steel fasteners or welds spaced max 24 in. (610 mm)
SAFTI SEAL INC — ST, STW or STX
MRI STEEL FRAMING LLC — Smart Slotted Track
SUPER STUD BUILDING PRODUCTS — Slotted Track
 - C. Studs — Steel studs to be min 3-1/2 in. (89 mm) wide. Studs cut 1/2 to 3/4 in. (13 to 19 mm) less in length than assembly height with bottom nesting in and resting on floor runner and with top nesting in ceiling runner (Item 3B) steel studs secured to slotted ceiling runner with No. 8 by 1/2 in. (13 mm) long wafer head steel screws at mid-height of slot on min. one side of wall. Stud spacing not to exceed 24 in. (610 mm) OC.
 - D. Gypsum Board* — Gypsum board sheets installed to a min total thickness of 5/8 in. (16 mm) and 1-1/4 in. (32 mm) on each side of wall for 1 and 2 hr rated assemblies, respectively. Wall to be constructed as specified in the individual Wall and Partition Design in the UL Fire Resistance Directory, except that a nom 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the bottom of the steel floor units and the top row of screws shall be installed into the studs a min of 4 in. (102 mm) below the lower surface of the floor.
The hourly fire rating of the joint system is equal to the hourly fire rating of the wall.
4. Fill, Void or Cavity Material* — Caulk or Sealant — Max separation between corrugated steel strap and top of wall is 1 in. (25 mm). The joint system is designed to accommodate a max 25 percent compression or extension from its installed width. Min 5/8 in. (16 mm) thickness of fill material installed on each side of the wall between the top of the gypsum board and the bottom of floor, flush with each surface of wall.
A/D FIRE PROTECTION SYSTEMS INC — A/D FireBarrier Acrylic Sealant
EGS NELSON FIRESTOP — ES 1399 Sealant
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP601S or CFS-S SIL GG Sealant
SPECIFIED TECHNOLOGIES INC — SpecSeal ES Sealant, Pensil 300 Sealant, SIL300 Sealant
TREMCO INC — TREMstop Acrylic or Fyre-Sil
DAP PRODUCTS INC — DAP Fire Stop Fire-Rated Silicone Sealant
UNITED STATES GYPSUM CO — Type A
5. Fill, Void or Cavity Material* - Sealant or Caulk — (Optional, not shown) - Min 1/8 in. (3.2 mm) bead of sealant applied at base of outside leg of corrugated ribs prior to fastening of corrugated steel strap to adjacent valleys. Any Fill, Void or Cavity Materials* sealant or caulk may be used.



Firestop Configuration C

2. Corrugated Steel Straps* — A continuous length of No. 20 ga galv corrugated steel strap to span the flute with ribs extending into flute cavity at the intersection of the valley surface and flute walls and overlapping the adjacent valleys 1 1/2 in. (38 mm). The steel strip is to be fastened to the floor assembly with typical steel fasteners or welds 16 in. (406 mm) O.C on both valleys. When wall length exceeds length of strap, straps are to be tightly butted or overlapped and fastened a max 2 in. (51 mm) from ends.

SAFTI SEAL INC — Safti-Frame FC (Flute Cover) Series

3. Wall Assembly — The 1 hr or 2 fire rated gypsum board/steel stud wall assembly shall be constructed of the materials and in the manner described in the individual U400 or V400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:

A. Steel Floor Runners — Floor runners of wall assembly shall consist of galv steel channels sized to accommodate steel studs (Item 3C).

B. Light Gauge Framing* - Slotted Ceiling Runner — Slotted ceiling runner to consist of galv steel channel with slotted flanges sized to accommodate steel studs (Item 3C). Slotted ceiling runner installed parallel to direction of fluted deck secured to valleys or corrugated steel straps with typical steel fasteners or welds spaced max 24 in. (610 mm)

SAFTI SEAL INC — ST, STW or STX

MRI STEEL FRAMING LLC — Smart Slotted Track

SUPER STUD BUILDING PRODUCTS — Slotted Track

C. Studs — Steel studs to be min 3-1/2 in. (89 mm) wide. Studs cut 1/2 to 3/4 in. (13 to 19 mm) less in length than assembly height with bottom nesting in and resting on floor runner and with top nesting in ceiling runner (Item 3B) steel studs secured to slotted ceiling runner with No. 8 by 1/2 in. (13 mm) long wafer head steel screws at mid-height of slot on min. one side of wall. Stud spacing not to exceed 24 in. (610 mm) OC.

D. Gypsum Board* — Gypsum board sheets installed to a min total thickness of 5/8 in. (16 mm) and 1-1/4 in. (32 mm) on each side of wall for 1 and 2 hr rated assemblies, respectively. Wall to be constructed as specified in the individual Wall and Partition Design in the UL Fire Resistance Directory, except that a nom 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the bottom of the steel floor units and the top row of screws shall be installed into the studs a min of 4 in. (102 mm) below the lower surface of the floor. The hourly fire rating of the joint system is equal to the hourly fire rating of the wall.

4. Fill, Void or Cavity Material* — Sealant — Max separation between bottom of fluted deck or corrugated steel strap and top of wall is 1 in. (25 mm). The joint system is designed to accommodate a max 25 percent compression or extension from its installed width. Min 5/8 in. (16 mm) thickness of fill material installed on each side of the wall between the top of the gypsum board and the bottom of floor, flush with each surface of wall.

A/D FIRE PROTECTION SYSTEMS INC — A/D FireBarrier Acrylic Sealant

EGS NELSON FIRESTOP — ES 1399 Sealant

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP601S or CFS-S SIL GG Sealant

SPECIFIED TECHNOLOGIES INC — SpecSeal ES Sealant, Pensil 300 Sealant, SIL300 Sealant

TREMCO INC — TREMstop Acrylic or Fyre-Sil

DAP PRODUCTS INC — DAP Fire Stop Fire-Rated Silicone Sealant

UNITED STATES GYPSUM CO — Type A

5. Fill, Void or Cavity Material* - Sealant or Caulk — (Optional, Not Shown) - Min 1/8 in. (3.2 mm) bead of sealant applied at base of outside leg of corrugated ribs prior to fastening of corrugated steel strap to adjacent valleys. Any Fill, Void or Cavity Materials* sealant or caulk may be used.

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

