




NOTE(S):

A. VERTICAL CABLE TRAY SHALL HAVE A MINIMUM OF TWO SUPPORT POINTS.

| No. | Unit Qty | Unit | Description | Box Qty | # Boxes Needed | Item No. |
|-----|----------|------|-----------------------------|---------|-------------------|----------|
| 1 | AS REQ'D | EA | GIRDER MI-90 3M | 1 | AS REQ'D | 304798 |
| 2 | AS REQ'D | EA | STRUT HS-158-12/HDG 10' | 1 | AS REQ'D | 407570 |
| 3 | 2 | EA | GIRDER END CAP MIA-EC90 | 25 | 1 | 432077 |
| 4 | 4 | EA | CHANNEL END CAP MEK RED | 50 | 1 | 244886 |
| 5 | 1 | PR | CONNECTOR MIC-T | 2 | 1 | 304807 |
| 6 | 2 | EA | HEX HEAD BOLT HDG 3/8"x1" | VARIES | VARIES | SPECIAL |
| 7 | 2 | EA | WING NUT MQM-F3/8"-F | 25 | 1 | 304136 |
| 8 | 2 | EA | ONEHAND SCREW MIA-OH90 | 10 | 1 | 304889 |
| 9 | 2 | EA | MI HEX NUT M12-F-SL-WS 3/4" | 100 | 1 | 382897 |





NOTE(S):

- PRELIMINARY NOT FOR CONSTRUCTION
- 2. DESIGN ASSUMPTIONS:
 - a. NO LOADS CONSIDERED CONCEPT ONLY
 - b. LATERAL LOADS NOT CONSIDERED
 - c. BUILDING CODE: NOT SPECIFIED
 - d. CORROSION RESISTANCE REQD.: HDG/SS
- 2. REFER TO COMPONENT MANUFACTURER'S IFUS FOR REQUIRED INSTALLATION INFO.
- 3. E.O.R. MUST BE NOTIFIED OF ANY DEVIATIONS FROM EXISTING/ NEW SUBSTRATE CONDITIONS SHOWN HEREIN TO VALIDATE ACCEPTANCE OF THIS HILTI DESIGN PRIOR TO INSTALLATION.



All loading and design criteria supplied by customer is assumed accurate. Only the stated Design Assumptions were considered, and must be verified by the responsible Engineer of Record (EOR). The basis of Hilti component and connection design is the published data in the current Hilti Technical Guide, including material and cross-section properties, allowable load values, factors of safety, methods of calculation, and limiting factors. The EOR must verify suitability for any specific application, and the capacity of the supportive structure to receive the shown configuration and associated reaction loads. Modification to components and/or design may alter performance and must be evaluated by the EOR.

TYPICAL DETAIL TYPE:

CABLE TRAY SUPPORT

TYPICAL DETAIL DESCRIPTION:

WELDED CANTILEVER SINGLE - VERTICAL

| DESIGNED BY: | REVIEWED BY: | |
|--------------|--------------|--|
| KL | AJV | |
| | | |
| | | |
| DRAWN BY: | ISSUE DATE: | |
| GAB | 02 JAN 15 | |
| | | |
| | | |

| REV | ISIONS: | |
|----------|----------------|------------|
| NO: | DESCRIPTION: | DATE: |
| <u>A</u> | ORIGINAL ISSUE | _02 JAN 15 |
| _ | | |
| _ | | |
| _ | | |
| _ | | |
| _ | | |
| _ | | |
| _ | | |
| | | |
| | | |
| _ | | |
| _ | | |
| _ | - | |
| _ | | |
| _ | | |
| _ | | - |
| _ | | |
| _ | | |

TYPICAL DETAIL NOMENCLATURE:

CT-C07-S

| DRAWING NUMBER: | SHEET: |
|-----------------|--------|
| 01 | 1/1 |