

No.	Unit Qty	Unit	Description	Box Qty	#Boxes Needed	Item No.
1	AS REQ'D	EA	STRUT HS-158-12/HDG 10'	1	AS REQ'D	407570
2	AS REQ'D	EA	STRUT HS-158-12/HDG 10' B2B	1	AS REQ'D	2007087
3	12	EA	CHANNEL END CAP MEK RED	50	1	244886
4	2	EA	8-HOLE ANGLE MQW-8/90-F	10	1	304175
5	8	EA	CHANNEL CONNECTOR MQN	50	1	369623
6	2	EA	HEX HEAD BOLT HDG 3/8"x1"	VARIES	VARIES	SPECIAL
7	2	EA	WING NUT MQM-F3/8"-F	25	1	304136
8	4	EA	X-BTW10-24-6 SN12-R	100	1	377076
9	4	EA	WASHER 3/8" SS316	200	1	411780
10	4	EA	HEX NUT STANDARD 3/8" SS316	100	1	411775

- NOTE(S):
- 1. PRELIMINARY NOT FOR CONSTRUCTION
- 2. DESIGN ASSUMPTIONS:
 - a. NO LOADS CONSIDERED CONCEPT ONLY
- b. LATERAL LOADS NOT CONSIDERED
- c. BUILDING CODE: NOT SPECIFIED
- d. CORROSION RESISTANCE REQD.: NOT SPECIFIED
- REFER TO COMPONENT MANUFACTURER'S IFUS FOR REQUIRED 2. INSTALLATION INFO.
- E.O.R. MUST BE NOTIFIED OF ANY DEVIATIONS FROM EXISTING/ 3. NEW SUBSTRATE CONDITIONS SHOWN HEREIN TO VALIDATE ACCEPTANCE OF THIS HILTI DESIGN PRIOR TO INSTALLATION.



All loading and design criteria supplied by customer is assumed accurate. Only the stated Design Assumptions were considered, and must be verified by the responsible Engineer of Record (EOR). The basis of Hilti component and connection design is the published data in the current Hilti Technical Guide, including material and cross-section properties, allowable load values, factors of safety, methods of calculation, and limiting factors. The EOR must verify suitability for any specific application, and the capacity of the supportive structure to receive the shown configuration and associated reaction loads. Modification to components and/or design may alter performance and must be evaluated by the EOR

TYPICAL DETAIL TYPE:

CABLE TRAY SUPPORT

TYPICAL DETAIL DESCRIPTION:

CANTILEVER - VERTICAL

	_	
DESIGNED BY:	REVIEWED	DBY:
KL	AJV	
DRAWN BY:	ISSUE DATE: 04 DEC 14	
BAP		
REVISIONS:		
NO: DESCRIPTION:		DATE:
A ORIGINAL ISSUE		04 DEC 14
TYPICAL DETAIL NOMENCLATU		
CT-(C50-S	
DRAWING NUMBER:	SHEET:	
		1/1
01		