



No.	Unit Qty	Unit	Description	Box Qty	# Boxes Needed	Item No.
1	4	EA	BEAM CLAMP MI-DGC 90	4	1	233860
2	6	EA	GIRDER END CAP MIA-EC90	25	1	432077
3	AS REQ'D	EA	GIRDER MI-90 3M	1	AS REQ'D	304798
4	2	EA	THREADED ROD CONNECTOR MIC-TRC M12-1/2"	2	1	233856
5	6	EA	LOCK WASHER 1/2" HDG	VARIES	VARIES	SPECIAL
6	6	EA	HEX NUT 1/2" HDG	VARIES	VARIES	SPECIAL
7	4	EA	CHANNEL END CAP MEK RED	50	1	244886
8	AS REQ'D	EA	STRUT HS-158-12/HDG 10'	1	AS REQ'D	407570
9	AS REQ'D	EA	1/2" THREADED ROD HDG	VARIES	AS REQ'D	SPECIAL
10	2	EA	ONEHAND SCREW MIA-OH90	10	1	304889
11	2	EA	MI HEX NUT M12-F-SL-WS 3/4"	100	1	382897







All loading and design criteria supplied by customer is assumed accurate. Only the stated Design Assumptions were considered, and must be verified by the responsible Engineer of Record (EOR). The basis of Hilti component and connection design is the published data in the current Hilti Technical Guide, including material and cross-section properties, allowable load values, factors of safety, methods of calculation, and limiting factors. The EOR must verify suitability for any specific application, and the capacity of the supportive structure to receive the shown configuration and associated reaction loads. Modification to components and/or design may alter performance and must be evaluated by the EOR.

TYPICAL DETAIL TYPE:

CABLE TRAY SUPPORT

TYPICAL DETAIL DESCRIPTION:

TRAPEZE - SINGLE

DESIGNED BY:	REVIEWED BY:
KL	AJV
DRAWN BY:	ISSUE DATE:
GAB	31 DEC 14

REVISIONS:

NO:	DESCRIPTION:	DATE:
<u>A</u>	ORIGINAL ISSUE	_31 DEC 14_
_		
_		
_		
_		-
_		
_		
_		
_		
_		
_		
_		
_		
_		
_		
_		
-		
-		
_		
l		

TYPICAL DETAIL NOMENCLATURE:

CT-TR05-S

DRAWING NUMBER:	SHEET:
01	1/1