## CERTIFICATE OF COMPLIANCE

Certificate Number R13240

Report Reference R13240-20191126
Issue Date 2020-MARCH-11

Issued to: HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC

7250 Dallas Pky, Legacy Tower Suite 1000

Plano TX 75024

This certificate confirms that representative samples of

FILL, VOID OR CAVITY MATERIALS

Putty Stick identified as Hilti CP 618 for use in Through-

Penetration Firestop Systems.

Hilti CFS-D 1" Firestop Putty Discs to be used in Through-

Penetration Firestop Systems.

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1479, Fire Tests of Penetration Firestops.

CAN/ULC-S115, Method of Fire Tests of Firestops Systems

Additional Information: See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>

