

Confirmation

LEED

On 10 October 2017, Eurofins Product Testing A/S received a sample of cast in firestop device with the product name:

CP 680-P 2"

supplied by

Hilti Inc.


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH, testing standards (See test report no. 392-2017-00364402_H_EN).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m³ in both office and class room.

7 December 2017



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry



Thomas Bjerring
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.