

# Confirmation

## LEED

On 1 Oktober 2014, Eurofins Product Testing A/S received a sample of a joint sealing tape with the product name:

**CFS-SP WB = CP672**

supplied by

**Hilti Entwicklungsgesellschaft GmbH**

The sample was supplied as being representative of the manufactured product, and it has been tested as Waterproofing concrete/Masonry sealers in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test reports no. 392-2014-00218204\_02 and 392-2014-00261502rev2\_02).

**The test results of the tested adhesive indicate that the product qualifies for LEED 2009 and LEED v4 specifications on VOC emissions and/or VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of SCAQMD rule 1168 (2005)

21 April 2015



---

Maria Pelle  
Chemist



---

Janne R. Norup  
Chemist